




UC Davis Health Campus Education Building Retrocommissioning

Client Name: Dan Mendonsa (Energy Manager, UC Davis Health)

-Rhys Davis & Ranjith Narasimhamurthy

BACKGROUND

- UC Davis Health - critical facilities
- Education Building - Low-hanging fruit
- Energy Savings
- Retrocommissioning



PURPOSE



Control Programming




Equipment Failure




Schedule





ENERGY PROFILE

- Baseline period: 4/3/2019-4/2/2020
- Electricity Data
 - Some missing data; created linear model (OAT + Weekday vs. Electricity) to fill in missing data
- Hot Water Data
 - Had flow, supply, and return temperature (necessary to calculate kBTU)
- Chilled Water Data
 - Missing flow data; had to sum up all equipment CHW flows to estimate total




ENERGY PROFILE

- Average UC Davis classroom building EUI = 83 kBTU/sf

	Baseline			
	CHW	HW	Electricity	Total
Energy (MMBTU/year)	10,628	3,540	7,361	21,529
Cost (\$/year)	\$58,451	\$26,553	\$172,579	\$257,584
EUI (kBTU/sf)				119
MTCO ₂ e	63.8	187.6	194.2	445.6

EQUIPMENT ANALYSIS - AHU


- Most common AHU issues




EQUIPMENT ANALYSIS - VAVs

- Most common VAV issues

Datapoints Offline



Damper stuck



Minimum and maximum cooling flow setpoints overridden


Temperature setpoints too high or low

SAVINGS METHODOLOGY - BinSim Tool


OAT	Hrs/yr	RAT	SAT	MAT	% OSA	Total building load	Total AHU airflow	Average zone DAT	AHU cooling energy	AHU heating	Zone reheat	Fan speed	Supply Fan Power	Return Fan Power	Fan power	Fan energy
°F		°F	°F	°F		Btu/h	cfm	°F	kBtu	kBtu	kBtu	%	kW	kW	kW	kWh
108	3	74.5	55.0	79.5	15%	201,586	9,572	55.0	735	0	0	68%	6.4	2.4	8.8	26
106	3	74.5	55.0	79.2	15%	201,586	9,572	55.0	726	0	0	68%	6.4	2.4	8.8	26
104	1	74.5	55.0	78.9	15%	201,586	9,572	55.0	346	0	0	68%	6.4	2.4	8.8	12
102	9	74.5	55.0	78.6	15%	201,586	9,572	55.0	2,100	0	0	68%	6.4	2.4	8.8	76
100	23	74.5	55.0	78.3	15%	193,008	9,165	55.0	5,287	0	0	65%	5.8	2.2	8.0	182
98	25	74.5	55.0	78.0	15%	184,430	8,757	55.0	5,444	0	0	62%	5.2	1.9	7.2	179
96	55	74.5	55.0	77.7	15%	175,852	8,350	55.0	11,271	0	0	59%	4.7	1.7	6.4	353
94	58	74.5	55.0	77.4	15%	167,274	7,943	55.0	11,138	0	0	56%	4.2	1.6	5.7	332
92	71	74.5	55.0	77.1	15%	158,696	7,535	55.0	12,856	0	0	53%	3.7	1.4	5.1	365
90	81	74.5	55.0	76.8	15%	150,117	7,128	55.0	13,559	0	0	51%	3.3	1.2	4.6	368
88	98	74.5	55.0	76.5	15%	141,539	6,721	55.0	15,296	0	0	48%	3.0	1.1	4.1	398
86	49	74.5	55.0	76.2	15%	132,961	6,313	55.0	7,034	0	0	45%	2.6	1.0	3.6	177
84	114	74.5	55.0	75.9	15%	124,383	5,906	55.0	15,162	0	0	42%	2.4	0.9	3.3	371
82	98	74.5	55.0	75.6	15%	115,805	5,499	55.0	11,991	0	0	39%	2.2	0.8	3.0	290
80	127	74.5	55.0	75.3	15%	107,227	5,091	55.0	14,205	0	0	36%	2.0	0.7	2.7	346
78	162	74.5	56.3	75.0	15%	98,649	5,028	56.3	16,453	0	0	36%	2.0	0.7	2.7	436
76	121	74.5	57.7	74.7	15%	90,070	4,954	57.7	11,017	0	0	35%	1.9	0.7	2.7	320
74	116	74.5	59.0	74.0	100%	81,492	4,868	59.0	9,125	0	0	35%	1.9	0.7	2.6	303
72	102	74.5	60.3	72.0	100%	72,914	4,766	60.3	6,131	0	0	34%	1.9	0.7	2.6	263
70	121	74.5	61.7	70.0	100%	64,336	4,642	61.7	5,042	0	0	33%	1.8	0.7	2.5	305
68	54	74.5	63.0	68.0	100%	55,758	4,489	63.0	1,299	0	0	32%	1.8	0.7	2.5	133
66	134	74.5	64.3	66.0	100%	47,180	4,297	64.3	1,033	0	0	30%	1.8	0.7	2.4	325
64	151	74.5	65.0	65.0	90%	38,602	3,762	65.0	0	0	0	27%	1.7	0.6	2.4	359
62	161	74.5	65.0	65.0	76%	30,023	3,503	66.6	0	0	954	25%	1.7	0.6	2.4	384
60	241	74.5	65.0	65.0	66%	21,445	3,503	68.8	0	0	3,488	25%	1.7	0.6	2.4	573
58	207	74.5	65.0	65.0	58%	12,867	3,503	71.1	0	0	4,778	25%	1.7	0.6	2.4	493
56	183	74.5	65.0	65.0	51%	4,289	3,503	73.4	0	0	5,788	25%	1.7	0.6	2.4	436
54	204	70.5	65.0	65.0	33%	-4,289	3,503	71.6	0	0	5,127	25%	1.7	0.6	2.4	486
52	165	70.5	65.0	65.0	30%	-12,867	3,503	73.9	0	0	5,556	25%	1.7	0.6	2.4	393
50	112	70.5	65.0	65.0	27%	-21,445	3,503	76.2	0	0	4,736	25%	1.7	0.6	2.4	267
48	144	70.5	65.0	65.0	24%	-30,023	3,503	78.4	0	0	7,299	25%	1.7	0.6	2.4	342
46	116	70.5	65.0	65.0	22%	-38,602	3,503	80.7	0	0	6,873	25%	1.7	0.6	2.4	275
44	94	70.5	65.0	65.0	21%	-47,180	3,503	83.0	0	0	6,411	25%	1.7	0.6	2.4	225
42	81	70.5	65.0	65.0	19%	-55,758	3,503	85.2	0	0	6,232	25%	1.7	0.6	2.4	194
40	35	70.5	65.0	65.0	18%	-64,336	3,503	87.5	0	0	2,980	25%	1.7	0.6	2.4	83
38	39	70.5	65.0	65.0	17%	-72,914	3,503	89.8	0	0	3,618	25%	1.7	0.6	2.4	92
36	30	70.5	65.0	65.0	16%	-81,492	3,503	92.0	0	0	3,069	25%	1.7	0.6	2.4	71
34	34	70.5	65.0	65.0	15%	-90,070	3,503	94.3	0	0	3,803	25%	1.7	0.6	2.4	82
32	19	70.5	65.0	64.7	15%	-98,649	3,503	96.6	0	19	2,222	25%	1.7	0.6	2.4	44
30	10	70.5	65.0	64.4	15%	-107,227	3,503	98.8	0	22	1,280	25%	1.7	0.6	2.4	24
28	1	70.5	65.0	64.1	15%	-115,805	3,503	101.1	0	5	191	25%	1.7	0.6	2.4	3
TOTALS	3650								177,252	46	74,406					10,412

SCHEDULING - AHU


On weekdays with events in Spring Quater, final event endtimes for each AHU were much earlier than schedule



DISCHARGE AIR TEMPERATURE RESET



DUCT STATIC PRESSURE RESET



FAN COIL & AIR CONDITIONING UNIT SETPOINTS

- Based on a linear model created for temperature vs. unit runtime, **each degree that the setpoint is increased results in a decrease of ~200 hours of annual run time**

- We recommend raising the setpoints for all units to at least **78 degrees**

- ASHRAE 2015 provides a maximum server room temperature recommendation of 80 degrees for critical equipment, with higher allowable levels for most equipment - savings shown below

	Current				
	Estimated Setpoint	Suggested Setpoint	Current Run Hours/Year	Estimated New Run Hours/Year	% Reduction
FC11	72	78	3,154	1,840	42%
FC12	72	78	8,760	7,446	15%
FC21	69	78	8,760	6,920	21%
FC22	74	78	8,760	7,972	9%
FC23	67	78	5,694	3,416	39%
FC41	72	78	0	438	0%
FC42	75	78	3,592	2,978	17%
AC11	73	78	788	438	46%
AC21	60	78	8,760	4,993	43%
AC22	59	78	4,555	526	88%
AC31	68	78	3,767	1,752	53%
AC32	71	78	3,416	2,015	40%
AC41	68	78	3,154	1,226	63%
AC42	63	78	8,760	5,606	36%

RESULTS - ALL SPECIFIC RECOMMENDATIONS


Payback for Recommendations								
	Measure	Hours	Cost/ Hour	Labor Cost	Equipment/ Capital Cost	Ongoing Cost	Total Annual Savings	Payback (Years)
1	Equipment Issues	20	\$125	\$2,500	\$2,500	\$0	\$0	NA
2	Scheduling	10	\$125	\$1,250	\$0	\$300	\$19,037	0.3
3	DAT Reset	30	\$125	\$3,750	\$0	\$0	\$3,269	1.1
4	DSP Reset	50	\$125	\$6,250	\$0	\$0	\$3,302	1.9
5	FCU/ACU Setpoints	5	\$125	\$625	\$0	\$0	\$2,203	0.3
	All	115	\$125	\$14,375	\$2,500	\$300	\$27,811	0.6

RESULTS- OVERALL SAVINGS

Potential Annual Savings				
	CHW	HW	Electricity	Total Annual Savings
Energy (MMBTU/year)	794	1,668	466	2,928
Cost (\$/year)	\$4,365	\$12,513	\$10,932	\$27,811
MTCO2e	4.8	88.4	12.3	105.5

Pre vs. Post			
	Baseline	Post	Percent Decrease
Energy (MMBTU/year)	21,529	18,610	14%
Cost (\$/year)	\$257,584	\$230,013	11%
EUI (kBtu/sf)	119	103	14%
MTCO2e	445.6	340.3	24%


LONG-TERM RECOMMENDATIONS



ONGOING MEASUREMENT & VERIFICATION



MAINTENANCE PLAN



SCHEDULING

BIBLIOGRAPHY

- ❖ Mills, Evan. “Building Commissioning: A Golden Opportunity for Reducing Energy Costs and Greenhouse Gas Emissions in the United States.” *Energy Efficiency*, vol. 4, no. 2, May 2011, pp. 145–73. DOI.org (Crossref), doi:10.1007/s12053-011-9116-8
 - **A great meta-analysis of RCx studies with average costs, savings, and ECMs**
- ❖ Fumo, Nelson. “A Review on the Basics of Building Energy Estimation.” *Renewable and Sustainable Energy Reviews*, vol. 31, Mar. 2014, pp. 53–60. ScienceDirect, doi:10.1016/j.rser.2013.11.040.
 - **Taxonomy of various strategies for energy modeling and savings estimates**
- ❖ 60913.Pdf. <https://www.nrel.gov/docs/fy14osti/60913.pdf>. Accessed 22 Apr. 2020.
 - **Roadmap for effective RCx planning and performance implementation including a priority list for consideration of retrofit measures**
- ❖ White_paper_classrooms.Pdf. https://www.krueger-hvac.com/files/white%20papers/white_paper_classrooms.pdf. Accessed 22 Apr. 2020.
 - **ASHRAE standards for Ventilation effectiveness and Thermal Comfort**
- ❖ S. T. Taylor, “Resetting Setpoints Using Trim & Respond Logic,” p. 6
- ❖ S.T. Taylor, “VAV System Static Pressure Setpoint Reset,” *ASHRAE J.*, p. 9, 2007
 - **Static Pressure Reset and Discharge Air Temperature Reset**