
Sustainable Sanitation Block for Student's Mall: A Feasibility Study

— University of Abomey-Calavi, Benin —

Sam Rodriguez, Daisy Guitron, Joe Wildman, Kylie Bodle

Introduction & Outline

Background

Final Project
Definition

Methodology

Sector Results

Conclusion/
Recommendations

Benin

Project Statement

Evaluative Matrix,

Interior
Environment

University of
Abomey-Calavi

Goals

SWOT Analysis,

Rainwater
Collection

Project Framing

Energy

Wastewater
Management



Background



- A student mall on the University of Abomey-Calavi (UAC) campus lacks adequate sanitation resources
- Over 45,000 students attend UAC
- Approximately 500 people visit the mall each day

Project Statement


- Dr. Charlene Gaba, a researcher at UAC, requested a feasibility study on implementation of a sanitation block within the student mall
- We evaluated installation of a system utilizing:
 - Touchless, solar-powered sinks and toilets
 - A septic system for wastewater management
 - Rainwater catchment as a backup source to UAC-provided water

Methodology - SWOT Analysis

Strengths	Weaknesses
<ul style="list-style-type: none">- Land already acquired- Demand for sanitation- Many resources are available on alternative water systems design	<ul style="list-style-type: none">- Touchless faucets can be unreliable- Financial resources are unknown
Opportunities	Threats
<ul style="list-style-type: none">- Obvious need to improve hygiene and sanitation resources- Learning opportunity for students on sustainable, off-grid resources	<ul style="list-style-type: none">- Sourcing material and hardware may be challenging- Maintenance requirements- Cultural preferences for a bathroom are likely different than those in the U.S.

Design Considerations


- Four lenses of sustainability:
 - Environmental
 - Social
 - Technical
 - Financial



Indoor Environmental Quality Results

Areas

1. Air Quality
 - a. Air quality can impact respiratory health
 - b. Ventilation lowers health risks
2. Lighting
 - a. Natural and Artificial
3. Hand Hygiene
 - a. Hand washing and drying
4. Accessibility



Courtesy of Sketchup

Indoor Env. Quality Results

Ventilation Standards

Ventilation System	Relevant Codes	Specification
Mechanical	ICC Mechanical Code 401, 403 ASHAE/ANSI 90.1-2007	$\text{cfm} = 662 \text{ ft}^3/\text{min} (1125 \text{ m}^3/\text{hr})$ $\text{Bph} = 24 + (\text{cfm}-20000) \times 0.0012$ $\text{Pfan} = \text{bhp} \times 746 / E_{\text{motor}}$ → 1/2 HP (425 W) blower motor
Natural	ICC Mechanical Code 401, 402	7600-15,000 L/min - m ²
Hybrid	Combination of above	1/3 HP blower motor & 7,600 L/min - m ²
ICC = International Code Council ASHAE = American Society of Heating and Air-Conditioning Engineers ANSI = American National Standards Institute		

Indoor Env. Quality Results

Temperature/Lighting Standards

Facility System	Relevant Codes	Specification
Temperature	ICC Building Code S 1203	Maintain indoor temperature around 20°C (68°F)
Lighting	ICC Building Code Section 1204, ICC Mechanical code 402	Artificial light (107 lux at 30-in height) Natural light
Hand Hygiene	ICC Building Code Section 402, 604	Automatic faucets and hand-dryers
ICC = International Code Council		




Sun Tunnel


solarskylights.com

Indoor Env. Quality Results

Natural Ventilation



Mechanical Ventilation



Department of Energy. (1994). *Cooling Your Home Naturally* (No. DOE/CH10093-221). Retrieved from Department of Energy website: <https://www.nrel.gov/docs/legosti/old/15771.pdf>

Alfano, S. (2016, July 19). Whole-House Mechanical Ventilation, an Overview. Retrieved June 6, 2019, from Pro Remodeler website: <http://www.proremodeler.com/whole-house-mechanical-ventilation-overview>

Indoor Env. Quality Results

Accessibility

Facility Type	Relevant Codes	Specification
Restroom	ICC A117.1 Accessible and Usable Buildings and Facilities	Grab bars, sitting toilet clearances, ramp design, flat even floors
ICC = International Code Council		

Specified clearances for accessible toilets




FIGURE 1103.11.2.4(A)

WATER CLOSETS IN TYPE A UNITS - WATER CLOSET LOCATION




FIGURE 1103.11.2.4(B)

WATER CLOSETS IN TYPE A UNITS - MINIMUM CLEARANCE

Indoor Env. Quality Results

Lighting & Hand Hygiene

Components	Unit Cost	Total Quantity	Total Cost
LED Lights	\$0.90	20	\$18
Natural Light Fixtures (sun tunnel)	\$150	4	\$600
Hand Dryers (electric)	\$75	4	\$300 (~\$150/yr)
Faucets (automatic)	\$25	4	\$100
Total			\$1240

Paper towels \$3,700/year
 = (\$0.01/towel X 365 days X 500 people/day X 2 towels/person)

Ventilation Options

Options	Unit Cost	Total Quantity	Total Cost
Mechanical	\$500	2	\$1000
Natural	\$550	2	\$1100
Hybrid	\$675	2	\$1350



\$2590

Sector 2 - Rainwater Catchment Results

Collection Volume = Efficiency × Rainfall × Surface Area

- Abomey-Calavi gets ~1300 mm rainfall/year
- Efficiency = 85%
- Roof surface area must be determined

Two 4 m by 11 m roofs will collect 90 m³ water each year




Rainwater Catchment Results - Sizing

$$V_t = V_{t-1} + \text{Supply} - \text{Demand}$$

- V_t = water volume remaining
- V_{t-1} = water volume remaining from previous month
- $\text{Demand} = 4 \text{ m}^3$ (average monthly rainfall)

15 m³ tank volume required per building




Rainwater Catchment Results - Costs

	Unit Size	Dimensions (Diameter x Height, m)	Aprrx. Cost (USD)	No. of Units Required per Building	No. of Buildings	Total Cost (USD)
Storage tanks	15 m ³	2.6 x 3.25	\$2,670	1	2	\$5,340
	7.6 m ³	2.3 x 2.1	\$900	2		\$3,600*
	5.1 m ³	1.8 x 2.2	\$780	3		\$4,680
Gutters (PVC)	11 m	NA	\$180	2		\$720
First Flush Diverter	1.4 L	NA	\$40	1		\$80
Pumps	140 L/min	NA	\$500	1		\$1,000
NA = Not applicable						TOTAL

Sector 3 - Energy

- Solar energy system
- Optimum Tilt:
 - Fixed or adjust: 2 seasons, 4 seasons
- The facility will use solar energy to power the following:
 - Light bulbs
 - Touchless faucets
 - Squatting toilets/Urinals
 - Energy storage
 - Ventilation Fan



Energy Sage. (2019). *Storing Solar Energy: How solar batteries work.*

Available from:

<https://www.energysage.com/solar/solar-energy-storage/how-do-solar-batteries-work/>

Energy Results- Steps

1. Determine the energy consumption of electric devices powered by the solar panels
2. Select the rated power(watts) of solar panel
3. Determine the Daily, Monthly, and Annual Use
4. Find the Peak Sun Hour (PSH) of your region
5. Determine the off-grid PV System Capacity (kWp)
6. Determine the off-grid PV System Capacity (kWp)
7. Determine the off-grid PV System Yield (kWh/kWp) (i.e. system expected output)
8. Determine the number of needed modules
9. Determine the space needed for the amount of panels

$$\text{Off-grid PV System Capacity (kWp)} = \frac{\text{Daily Energy Use (kWh)}}{\text{Peak Sun Hours (hours)}} \quad (1)$$

$$\text{Off-grid PV System Yield (kWh/kWp)} = \frac{\text{Annual Energy Use (kWh)}}{\text{PV System Capacity (kWp)}} \quad (2)$$

$$\text{Number of needed modules} = \frac{\text{System Capacity (kWp)}}{\text{Module Rated Power (kW)}} \quad (3)$$

$$\text{System Expected Output} = \text{PV System Capacity} * \text{PV System Yield} \quad (4)$$

$$\text{Space needed} = \frac{\text{Roof Size (m}^2\text{)}}{10} * \text{kWp} \quad (5)$$

Energy Results- Power Output

Parameter	Units	Minimum	Maximum
Rated Power	Watts	200.00	400.
Daily Energy Use	kWh	11.0	53.8
Monthly Energy	kWh	328.78	1615
Annual Energy Use	kWh	3945.40	19378
Peak Sun Hours (PSH)	Hours	4.00	4.90

Parameter	Units	Minimum	Maximum
Daily Energy Demand	kWh	11.0	53.8
Off-grid PV system capacity	kW _p	2.74	11
Off-grid PV system Demand	kWh/year	3945	19378
Off-grid PV System Yield	kWh/kW _p	1440	1764
Number of PV modules needed	Each	14	27

- In total solar power system will provide **3,945 kWh annually**, .
- The men's building will have four urinals and three squatting toilets and the women will have seven squatting toilets. The total daily energy demand for both facilities is **21.92 kWh**.



Energy Results - Cost

Total Cost: \$34,912

Elements		Quantity	Min. Cost (\$)	Max. Cost (\$)
Energy System	Solar Panels	14	500	700
	stand-alone inverter	1	200	1000
	charge controller	1	20	100
	Low voltage disconnect	1	60	130
	AC/DC circuits	1	100	300
Facility Elements	Energy Storage	1	8,500	15,500
	LED Light Bulb	5	8	12
	Touchless Faucets	2	28	33
	Squatting Toilets	3	200	400
	Urinals	4	200	400
	Ventilation fans	2	40	100
Total			\$ 17,456	\$ 29,956

Decentralized Wastewater Treatment

- Primary and Secondary Treatment Technologies
- Parameters
 - 7 L/use
 - 500 users
 - $Q = 3.5 \text{ L/day}$
- Primary
 - Septic Tank
 - Holding Tank
 - Anaerobic Baffled Reactor (ABR)
- Secondary
 - Drainage Field
 - Constructed Wetlands



Septic and Holding Tanks

HRT = 1 day

Desludge every year

University already has multiple septic tanks

Holding Tank

- 4 times the size of a septic tank
- 194.4 m³
- Desludge every year

Unit	Value
Max Capacity for 24 hr Retention (L)	3500
Volume for sludge accumulation (L)	35000
Working Tank Volume m ³	39
Water Depth	1.5
Total Depth	1.8
Width	3
Length Compartment 1	6
Length Compartment 2	3
Total Length	9
Designed Tank Volume m ³	48.6

Anaerobic Baffled Reactor

- Baffles create a longer HRT
- Longer HRT for smaller footprint
- Better BOD removal 90% vs 25%

HRT (days)	2
Working Volume (m3)	7
Peak Upflow Velocity (m/hr)	0.54
Design Upflow Velocity (m/hr)	0.3
Number of Compartments	5
Hanging Baffle Clearance (m)	0.2
Upflow to downflow area ratio	3
Compartment width to length ratio	3
Reactor Depth (m)	2
Reactor width (m)	1.4
Reactor Length (m)	2.3
Volume (m3)	6.44
Sludge Accumulation rate (L/cap yr)	1.5
Sludge Accumulation (m/yr)	0.7
Desludge Rate (yr)	1.4

Drainage Field

- Large Area
- Potential groundwater pollution
- University uses ground water wells

Unit	Value
Infiltration (L/m ² day)	50
Wall Area (m ²)	70
Depth	0.6
Length (m)	116.7
Enough space for two trenches (m)	58
Width (m)	0.4
Volume of gravel (m ³)	28.1
Area (m ³)	46.68

Constructed Wetlands

Deguenon et al. 2009


- VF CW using Phragmite reeds at the University

Reed's Method

- calculate surface area based on BOD removal
- cross sectional area based on conductivity

Horizontal Subsurface Flow

Unit	Value
Cin	134
Ce	30
Surface Area (m ²)	18
Slope (dH/dS)	0.01
Cross-sectional Area (m ²)	5
width (m)	12.5
Length (m)	3.6



	Vault	Septic Tank + Drainage Field	Septic Tank + Constructed Wetlands	ABR + Drainage Field	ABR + Constructed Wetlands
Capacity (m³)	194.4	48.6	48.6	6.44	6.44
Foot Print (m²)	97.2	46.68	45	49.9	21.22
HRT (days)	N/A	1	1	2	2
BOD Removal	10%	25%%	90%	90%	90%
Pathogen Removal	0%	0%	N/A	0%	N/A
Sludge Removal Interval (years)	1	1	1	1.4	1.4
Maintenance	Periodically Desludging	Periodically Desludging	Periodically Desludging + Maintaining Health of Wetlands	Periodically Desludging	Periodically Desludging + Maintaining Health of Wetlands
Total Capital Cost¹	\$ 3,600	\$ 12,300	\$ 3,7	\$ 11,400	\$ 3,315
Operational Cost/year¹	\$ 3,524	\$ 811	\$ 811	\$ 117	\$ 117

Final Details

- Rainwater catchment will provide $\sim 4 \text{ m}^3$ of water per month
- Indoor environmental quality will be maintained with an active or hybrid ventilation system
- Solar energy will be used to power faucets, toilets, lighting, and a fan for ventilation
- Decentralized WW management will be achieved with ABR-Constructed Wetlands system
- Final cost = \$46,000

